

FORM R405-2017




FLORIDA ENERGY EFFICIENCY CODE FOR BUILDING CONSTRUCTION

Florida Department of Business and Professional Regulation - Residential Performance Method

Project Name: 425 HOGANS ST (S) - TYPE II-ALT Street: 425 HOGANS ST City, State, Zip: WEST PALM BEACH, FL Owner: MERRYPLACE HOMES Design Location: FL, West Palm Beach	Builder Name: Permit Office: WEST PALM BEACH Permit Number: Jurisdiction: 604700 County: Palm Beach (Florida Climate Zone 1)
---	---

<table style="width: 100%;"> <tr> <td style="width: 50%;">1. New construction or existing</td> <td style="width: 50%;">New (From Plans)</td> </tr> <tr> <td>2. Single family or multiple family</td> <td>Single-family</td> </tr> <tr> <td>3. Number of units, if multiple family</td> <td>1</td> </tr> <tr> <td>4. Number of Bedrooms</td> <td>3</td> </tr> <tr> <td>5. Is this a worst case?</td> <td>No</td> </tr> <tr> <td>6. Conditioned floor area above grade (ft²)</td> <td>1478</td> </tr> <tr> <td>Conditioned floor area below grade (ft²)</td> <td>0</td> </tr> <tr> <td>7. Windows (250.0 sqft.)</td> <td> <table style="width: 100%;"> <tr> <th>Description</th> <th>Area</th> </tr> <tr> <td>a. U-Factor: Sgl. U=1.11</td> <td>249.99 ft²</td> </tr> <tr> <td>SHGC: SHGC=0.39</td> <td></td> </tr> <tr> <td>b. U-Factor: N/A</td> <td>ft²</td> </tr> <tr> <td>SHGC:</td> <td></td> </tr> <tr> <td>c. U-Factor: N/A</td> <td>ft²</td> </tr> <tr> <td>SHGC:</td> <td></td> </tr> <tr> <td>d. U-Factor: N/A</td> <td>ft²</td> </tr> <tr> <td>SHGC:</td> <td></td> </tr> <tr> <td>Area Weighted Average Overhang Depth:</td> <td>5.112 ft.</td> </tr> <tr> <td>Area Weighted Average SHGC:</td> <td>0.390</td> </tr> </table> </td> </tr> <tr> <td>8. Floor Types (1478.0 sqft.)</td> <td> <table style="width: 100%;"> <tr> <th>Insulation</th> <th>Area</th> </tr> <tr> <td>a. Slab-On-Grade Edge Insulation</td> <td>R=0.0 1478.00 ft²</td> </tr> <tr> <td>b. N/A</td> <td>R= ft²</td> </tr> <tr> <td>c. N/A</td> <td>R= ft²</td> </tr> </table> </td> </tr> </table>	1. New construction or existing	New (From Plans)	2. Single family or multiple family	Single-family	3. Number of units, if multiple family	1	4. Number of Bedrooms	3	5. Is this a worst case?	No	6. Conditioned floor area above grade (ft²)	1478	Conditioned floor area below grade (ft²)	0	7. Windows (250.0 sqft.)	<table style="width: 100%;"> <tr> <th>Description</th> <th>Area</th> </tr> <tr> <td>a. U-Factor: Sgl. U=1.11</td> <td>249.99 ft²</td> </tr> <tr> <td>SHGC: SHGC=0.39</td> <td></td> </tr> <tr> <td>b. U-Factor: N/A</td> <td>ft²</td> </tr> <tr> <td>SHGC:</td> <td></td> </tr> <tr> <td>c. U-Factor: N/A</td> <td>ft²</td> </tr> <tr> <td>SHGC:</td> <td></td> </tr> <tr> <td>d. U-Factor: N/A</td> <td>ft²</td> </tr> <tr> <td>SHGC:</td> <td></td> </tr> <tr> <td>Area Weighted Average Overhang Depth:</td> <td>5.112 ft.</td> </tr> <tr> <td>Area Weighted Average SHGC:</td> <td>0.390</td> </tr> </table>	Description	Area	a. U-Factor: Sgl. U=1.11	249.99 ft²	SHGC: SHGC=0.39		b. U-Factor: N/A	ft²	SHGC:		c. U-Factor: N/A	ft²	SHGC:		d. U-Factor: N/A	ft²	SHGC:		Area Weighted Average Overhang Depth:	5.112 ft.	Area Weighted Average SHGC:	0.390	8. Floor Types (1478.0 sqft.)	<table style="width: 100%;"> <tr> <th>Insulation</th> <th>Area</th> </tr> <tr> <td>a. Slab-On-Grade Edge Insulation</td> <td>R=0.0 1478.00 ft²</td> </tr> <tr> <td>b. N/A</td> <td>R= ft²</td> </tr> <tr> <td>c. N/A</td> <td>R= ft²</td> </tr> </table>	Insulation	Area	a. Slab-On-Grade Edge Insulation	R=0.0 1478.00 ft²	b. N/A	R= ft²	c. N/A	R= ft²	<table style="width: 100%;"> <tr> <td style="width: 50%;">9. Wall Types (1698.1 sqft.)</td> <td style="width: 50%;">Insulation Area</td> </tr> <tr> <td>a. Concrete Block - Int Insul, Exterior</td> <td>R=4.1 1324.90 ft²</td> </tr> <tr> <td>b. Frame - Wood, Adjacent</td> <td>R=11.0 373.20 ft²</td> </tr> <tr> <td>c. N/A</td> <td>R= ft²</td> </tr> <tr> <td>d. N/A</td> <td>R= ft²</td> </tr> <tr> <td>10. Ceiling Types (1523.0 sqft.)</td> <td>Insulation Area</td> </tr> <tr> <td>a. Under Attic (Vented)</td> <td>R=30.0 1523.00 ft²</td> </tr> <tr> <td>b. N/A</td> <td>R= ft²</td> </tr> <tr> <td>c. N/A</td> <td>R= ft²</td> </tr> <tr> <td>11. Ducts</td> <td>R ft²</td> </tr> <tr> <td>a. Sup: Attic, Ret: Attic, AH: System 1</td> <td>6 399</td> </tr> <tr> <td>12. Cooling systems</td> <td>kBtu/hr Efficiency</td> </tr> <tr> <td>a. Central Unit</td> <td>35.0 SEER:16.00</td> </tr> <tr> <td>13. Heating systems</td> <td>kBtu/hr Efficiency</td> </tr> <tr> <td>a. Electric Strip Heat</td> <td>27.0 COP:1.00</td> </tr> <tr> <td>14. Hot water systems</td> <td></td> </tr> <tr> <td>a. Electric</td> <td>Cap: 40 gallons</td> </tr> <tr> <td>b. Conservation features</td> <td>EF: 0.950</td> </tr> <tr> <td>15. Credits</td> <td>Pstat</td> </tr> </table>	9. Wall Types (1698.1 sqft.)	Insulation Area	a. Concrete Block - Int Insul, Exterior	R=4.1 1324.90 ft²	b. Frame - Wood, Adjacent	R=11.0 373.20 ft²	c. N/A	R= ft²	d. N/A	R= ft²	10. Ceiling Types (1523.0 sqft.)	Insulation Area	a. Under Attic (Vented)	R=30.0 1523.00 ft²	b. N/A	R= ft²	c. N/A	R= ft²	11. Ducts	R ft²	a. Sup: Attic, Ret: Attic, AH: System 1	6 399	12. Cooling systems	kBtu/hr Efficiency	a. Central Unit	35.0 SEER:16.00	13. Heating systems	kBtu/hr Efficiency	a. Electric Strip Heat	27.0 COP:1.00	14. Hot water systems		a. Electric	Cap: 40 gallons	b. Conservation features	EF: 0.950	15. Credits	Pstat
1. New construction or existing	New (From Plans)																																																																																						
2. Single family or multiple family	Single-family																																																																																						
3. Number of units, if multiple family	1																																																																																						
4. Number of Bedrooms	3																																																																																						
5. Is this a worst case?	No																																																																																						
6. Conditioned floor area above grade (ft²)	1478																																																																																						
Conditioned floor area below grade (ft²)	0																																																																																						
7. Windows (250.0 sqft.)	<table style="width: 100%;"> <tr> <th>Description</th> <th>Area</th> </tr> <tr> <td>a. U-Factor: Sgl. U=1.11</td> <td>249.99 ft²</td> </tr> <tr> <td>SHGC: SHGC=0.39</td> <td></td> </tr> <tr> <td>b. U-Factor: N/A</td> <td>ft²</td> </tr> <tr> <td>SHGC:</td> <td></td> </tr> <tr> <td>c. U-Factor: N/A</td> <td>ft²</td> </tr> <tr> <td>SHGC:</td> <td></td> </tr> <tr> <td>d. U-Factor: N/A</td> <td>ft²</td> </tr> <tr> <td>SHGC:</td> <td></td> </tr> <tr> <td>Area Weighted Average Overhang Depth:</td> <td>5.112 ft.</td> </tr> <tr> <td>Area Weighted Average SHGC:</td> <td>0.390</td> </tr> </table>	Description	Area	a. U-Factor: Sgl. U=1.11	249.99 ft²	SHGC: SHGC=0.39		b. U-Factor: N/A	ft²	SHGC:		c. U-Factor: N/A	ft²	SHGC:		d. U-Factor: N/A	ft²	SHGC:		Area Weighted Average Overhang Depth:	5.112 ft.	Area Weighted Average SHGC:	0.390																																																																
Description	Area																																																																																						
a. U-Factor: Sgl. U=1.11	249.99 ft²																																																																																						
SHGC: SHGC=0.39																																																																																							
b. U-Factor: N/A	ft²																																																																																						
SHGC:																																																																																							
c. U-Factor: N/A	ft²																																																																																						
SHGC:																																																																																							
d. U-Factor: N/A	ft²																																																																																						
SHGC:																																																																																							
Area Weighted Average Overhang Depth:	5.112 ft.																																																																																						
Area Weighted Average SHGC:	0.390																																																																																						
8. Floor Types (1478.0 sqft.)	<table style="width: 100%;"> <tr> <th>Insulation</th> <th>Area</th> </tr> <tr> <td>a. Slab-On-Grade Edge Insulation</td> <td>R=0.0 1478.00 ft²</td> </tr> <tr> <td>b. N/A</td> <td>R= ft²</td> </tr> <tr> <td>c. N/A</td> <td>R= ft²</td> </tr> </table>	Insulation	Area	a. Slab-On-Grade Edge Insulation	R=0.0 1478.00 ft²	b. N/A	R= ft²	c. N/A	R= ft²																																																																														
Insulation	Area																																																																																						
a. Slab-On-Grade Edge Insulation	R=0.0 1478.00 ft²																																																																																						
b. N/A	R= ft²																																																																																						
c. N/A	R= ft²																																																																																						
9. Wall Types (1698.1 sqft.)	Insulation Area																																																																																						
a. Concrete Block - Int Insul, Exterior	R=4.1 1324.90 ft²																																																																																						
b. Frame - Wood, Adjacent	R=11.0 373.20 ft²																																																																																						
c. N/A	R= ft²																																																																																						
d. N/A	R= ft²																																																																																						
10. Ceiling Types (1523.0 sqft.)	Insulation Area																																																																																						
a. Under Attic (Vented)	R=30.0 1523.00 ft²																																																																																						
b. N/A	R= ft²																																																																																						
c. N/A	R= ft²																																																																																						
11. Ducts	R ft²																																																																																						
a. Sup: Attic, Ret: Attic, AH: System 1	6 399																																																																																						
12. Cooling systems	kBtu/hr Efficiency																																																																																						
a. Central Unit	35.0 SEER:16.00																																																																																						
13. Heating systems	kBtu/hr Efficiency																																																																																						
a. Electric Strip Heat	27.0 COP:1.00																																																																																						
14. Hot water systems																																																																																							
a. Electric	Cap: 40 gallons																																																																																						
b. Conservation features	EF: 0.950																																																																																						
15. Credits	Pstat																																																																																						

Glass/Floor Area: 0.169	Total Proposed Modified Loads: 65.33	PASS
	Total Baseline Loads: 65.83	

I hereby certify that the plans and specifications covered by this calculation are in compliance with the Florida Energy Code. DocuSigned by:  PREPARED BY: Karen Oliver DATE: 561477A05D2941E 9/22/2020 (561) 327-7272 I hereby certify that this building, as designed, is in compliance with the Florida Energy Code. OWNER/AGENT:  DATE: 1-13-20	Review of the plans and specifications covered by this calculation indicates compliance with the Florida Energy Code. Before construction is completed this building will be inspected for compliance with Section 553.908 Florida Statutes.  BUILDING OFFICIAL: DATE:
--	--

- Compliance requires certification by the air handler unit manufacturer that the air handler enclosure qualifies as certified factory-sealed in accordance with R403.3.2.1.
- Compliance requires an Air Barrier and Insulation Inspection Checklist in accordance with R402.4.1.1 and this project requires an envelope leakage test report with envelope leakage no greater than 7.00 ACH50 (R402.4.1.2).

CITY OF WEST PALM BEACH
DEVELOPMENT SERVICES DEPARTMENT



17120258

04/26/21

OFFICIAL PERMIT RECORD