

SYS #	TONS	MANUF.	UNIT MODEL	MCA/ MOCP	UNIT #	A.H.U UNIT MODEL	CFM TOTAL	SEER	COOL BTUH	HEAT KW	AHRI CERT	SUC & LIQ LINE SIZE
1	3.0	GOODMAN	GSX160361F*	MFG	1	ASPT47D14A*	1200	16	35000	8	201384313	7/8"& 3/8"

LEGEND

A

CFM

10x10 SUPPLY GRILLE

B

CFM

6x6 SUPPLY GRILLE

50 CFM EXHAUST FAN (V.T.O.)

RETURN AIR DUCT

SUPPLY AIR DUCT

4" Ø FLEX DUCT

3/4" PVC DRAIN LINE

REF LINES ON EXTERIOR OF BUILDING WALL IN PROTECTIVE METAL LINE CHASE, PAINT TO MATCH WALL

NOTE: THERE CAN BE NO OVERHANG OR OBSTRUCTION TO AIR FLOW DIRECTLY ABOVE CONDENSING UNIT

MIN 4 MIAMI-DADE APPROVED TIE DOWN CLIPS INSTALLED AS PER PROVIDED PRODUCT APPROVAL

4" CONCRETE SLAB 3" ABOVE ADJOINING FINISHED GRADE AS PER FMC 304.10 2-1/2" BEYOND UNIT ON ALL SIDES.

12" MIN

C.U. MOUNTING DETAIL

NOTES

REF LINES ON EXTERIOR OF BUILDING WALL IN PROTECTIVE METAL LINE CHASE, PAINT TO MATCH WALL.

NOTE: THERE CAN BE NO OVERHANG OR OBSTRUCTION TO AIR FLOW DIRECTLY ABOVE CONDENSING UNIT

MIN 4 MIAMI-DADE APPROVED TIE DOWN CLIPS INSTALLED AS PER PROVIDED PRODUCT APPROVAL

12" MIN

4" CONCRETE SLAB 3" ABOVE ADJOINING FINISHED GRADE AS PER FMC 304.10 2-1/2" BEYOND UNIT ON ALL SIDES.

C.U. MOUNTING DETAIL NTS